


NOTES:

- A. ALL FIRE LINES MUST HAVE AT LEAST 3.5 FEET OF GROUND COVER.
- B. USE BALL VALVES AS MANUFACTURED BY FORD, McDONALD, OR APPROVED EQUAL.

<p>REVISIONS</p> 	<p>SINGLE FAMILY RESIDENTIAL FIRE LINE SYSTEMS—EXISTING HOMES</p>	<p>DRAWING NO.</p> <p style="text-align: center; font-size: 24pt;">177</p>
--	---	--